

Sampling Point	Sampling date	PFBS <sub>2</sub>	PFPS <sub>1,3</sub>	PFHS <sub>4</sub>	TDFOS <sub>5</sub>	PFHpS <sub>1,6</sub>	PFOS <sub>7</sub>	TDFOXAS <sub>11,8</sub>	TDFOPAS <sub>11,8</sub>	PFOA <sub>9</sub>
<b>Sampling Point Levitha</b>										
Levitha	23/02/2016	Nd	0.032	0.55	Nd	0.010	0.17	Nd	Nd	0.14
<b>Sampling Point Mont a la Brune Housing Estate</b>										
Mont a la Brune Housing Estate	05/07/1999	-	-	Nd	-	-	-	-	-	-
Mont a la Brune Housing Estate	14/07/1999	-	-	Nd	-	-	Nd	-	-	-
Mont a la Brune Housing Estate	22/07/1999	-	-	Nd	-	-	Nd	-	-	-
Mont a la Brune Housing Estate	28/07/1999	-	-	Nd	-	-	Nd	-	-	-
Mont a la Brune Housing Estate	04/08/1999	-	-	Nd	-	-	Nd	-	-	-
Mont a la Brune Housing Estate	17/08/1999	-	-	Nd	-	-	Nd	-	-	-
Mont a la Brune Housing Estate	06/06/2006	-	-	-	-	-	0.02	-	-	-
Mont a la Brune Housing Estate	06/12/2006	Nd	0.02	0.04	Nd	Nd	0.19	Nd	Nd	Nd
Mont a la Brune Housing Estate	29/08/2008	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd
Mont a la Brune Housing Estate	19/12/2008	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd
Mont a la Brune Housing Estate	23/06/2009	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd
Mont a la Brune Housing Estate	20/01/2010	Nd	Nd	0.03	Nd	Nd	0.03	Nd	Nd	Nd
Mont a la Brune Housing Estate	14/02/2011	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd
Mont a la Brune Housing Estate	04/07/2011	0.09	Nd	0.04	Nd	Nd	Nd	Nd	Nd	0.12
Mont a la Brune Housing Estate	09/03/2012	0.013	Nd	0.039	Nd	Nd	Nd	Nd	Nd	Nd
Mont a la Brune Housing Estate	20/08/2012	Nd	Nd	0.028	Nd	Nd	Nd	Nd	Nd	Nd
Mont a la Brune Housing Estate	06/03/2013	0.02	Nd	0.03	Nd	Nd	Nd	Nd	Nd	Nd
Mont a la Brune Housing Estate	16/04/2014	Nd	Nd	0.057	Nd	Nd	Nd	Nd	Nd	Nd
Mont a la Brune Housing Estate	25/08/2015	Nd	Nd	0.04	Nd	Nd	Nd	Nd	Nd	Nd
Mont a la Brune Housing Estate	01/07/2016	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd
Mont a la Brune Housing Estate	05/12/2016	Nd	Nd	0.064	Nd	Nd	Nd	Nd	Nd	Nd
Mont a la Brune Housing Estate	05/12/2016	Nd	Nd	0.062	Nd	Nd	Nd	Nd	Nd	Nd
Mont a la Brune Housing Estate	05/12/2016	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	0.064/0.053	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>
<b>Sampling Point Les Capcons</b>										
Les Capcons	21/06/2011	0.071	0.038	0.30	nd	nd	0.17	nd	nd	0.17
Les Capcons	20/02/2012	0.016	0.027	0.2	nd	nd	0.095	nd	nd	nd
Les Capcons	09/08/2012	0.026/0.028 <sub>12</sub>	0.029/0.028 <sub>12</sub>	0.27/0.24 <sub>12</sub>	nd/nd <sub>12</sub>	nd/nd <sub>12</sub>	0.13/0.11 <sub>12</sub>	nd/nd <sub>12</sub>	nd/nd <sub>12</sub>	nd/nd <sub>12</sub>
Les Capcons	05/03/2013	0.02	nd	0.03	nd	nd	0.010	nd	nd	nd
Les Capcons	01/05/2014	nd	nd	0.16	nd	nd	0.068	nd	nd	nd
Les Capcons	15/03/2015	0.02	Nd	0.03	Nd	Nd	0.01	Nd	Nd	Nd
Les Capcons	21/11/2016	nd/nd <sub>12</sub>	1.3/1.5	nd/nd	nd/nd	nd/nd	0.38/0.45	nd/nd	nd/nd	nd/nd
<b>Sampling Point Tumbleside</b>										
Tumbleside	27/05/2015	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	0.039/0.041 <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>
<b>Sampling Point L'Hirondelle</b>										
L'Hirondelle	01/09/1999	-	-	-	-	-	-	-	-	-
L'Hirondelle	08/09/1999	-	-	-	-	-	nd	-	-	-
L'Hirondelle	15/09/1999	-	-	-	-	-	nd	-	-	-
L'Hirondelle	23/09/1999	-	-	-	-	-	nd	-	-	-
L'Hirondelle	29/09/1999	-	-	-	-	-	nd	-	-	-
L'Hirondelle	06/10/1999	-	-	-	-	-	nd	-	-	-
L'Hirondelle	13/10/1999	-	-	-	-	-	nd	-	-	-
L'Hirondelle		-	-	-	-	-	-	-	-	-
L'Hirondelle	26/05/2015	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	0.079
L'Hirondelle	12/07/2016	Nd	Nd	0.026	Nd	Nd	Nd	Nd	Nd	Nd
<b>Sampling Point La Cachette</b>										
La Cachette	07/04/1999	-	-	-	-	-	-	-	-	-
La Cachette	10/11/2005	-	-	0.61	-	-	0.92	-	-	-
La Cachette	12/06/2006	Nd	Nd	0.11	Nd	Nd	0.08	Nd	Nd	nd
La Cachette	06/12/2006	0.07	0.04	0.26	Nd	Nd	0.24	Nd	Nd	0.02
La Cachette	24/05/2010	0.082	0.028	0.25	Nd	Nd	0.14	Nd	Nd	0.061
La Cachette	07/02/2011	Nd	0.04	0.45	Nd	Nd	0.23	Nd	Nd	Nd
La Cachette	13/06/2011	0.089	0.036	0.37	Nd	Nd	0.13	Nd	Nd	Nd
La Cachette	22/02/2012	0.056	0.069	0.58	Nd	Nd	0.19	Nd	Nd	Nd
La Cachette	16/08/2012	0.041	0.029	0.26	Nd	Nd	0.10	Nd	Nd	Nd
La Cachette	05/03/2013	0.04	Nd	0.26	Nd	Nd	0.06	Nd	Nd	Nd
La Cachette	17/04/2014	0.05	0.046	0.49	Nd	Nd	0.20	Nd	Nd	0.038
La Cachette	07/09/2015	Nd	Nd	0.43	Nd	Nd	0.15	Nd	Nd	0.063
La Cachette	24/06/2016	Nd	Nd	0.39	Nd	Nd	0.14	Nd	Nd	0.035
<b>Sampling Point La Grange</b>										
La Grange	10/11/2005	-	-	0.48	-	-	-	-	-	-
La Grange	12/06/2006	0.04	0.11	0.68	0.75	0.03	0.64	Nd	Nd	nd
La Grange	06/12/2006	0.036	0.067	0.31	Nd	0.013	0.35	Nd	Nd	0.023
La Grange	24/05/2010	0.12	0.12	1.3	Nd	0.044	1.30	Nd	Nd	0.12
La Grange	07/02/2011	Nd	0.05	0.45	Nd	Nd	0.42	Nd	Nd	0.04
La Grange	13/06/2011	0.11	0.055	0.55	Nd	0.011	0.39	Nd	Nd	0.098
La Grange	22/02/2012	0.052	0.076	0.58	Nd	0.015	0.44	Nd	Nd	0.050
La Grange	15/08/2012	0.049	0.058	0.61	Nd	0.012	0.47	Nd	Nd	0.051
La Grange	05/03/2013	0.05	Nd	0.38	Nd	Nd	0.23	Nd	Nd	Nd
La Grange	17/04/2014	0.063	0.066	0.59	Nd	Nd	0.38	Nd	Nd	0.057
La Grange	07/09/2015	Nd	Nd	0.42	Nd	Nd	0.28	Nd	Nd	0.056
La Grange	24/06/2016	Nd	Nd	0.54	Nd	Nd	0.26	Nd	Nd	0.033
<b>Sampling Point Val De La Mare Farm House, Cottage &amp; Workshop</b>										
Val de la Mare Farm House	06/04/1999	-	-	-	-	-	-	-	-	-
Val de la Mare Farm House	10/11/2005	-	0.54	2.5	-	-	1.60	-	-	-
Val de la Mare Farm House	05/06/2006	0.09	0.14	1.3	0.79	0.06	1.80	Nd	0.68	0.014
Val de la Mare Farm House	06/12/2006	0.088	0.17	0.97	Nd	0.028	1.30	Nd	Nd	0.085
Val de la Mare Farm House	10/01/2008	-	0.54	2.5	-	-	1.60	-	-	-
Val de la Mare Farm House	12/03/2009	Nd	Nd	Nd	Nd	Nd	0.05	Nd	Nd	Nd
Val de la Mare Farm House	23/06/2009	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd
Val de la Mare Farm House	22/02/2017	Nd	0.05	0.97	Nd	0.2	1.4	Nd	Nd	0.11
Val de la Mare Farm Cottage	10/11/2005	-	-	-	-	-	0.90	-	-	-
Val de la Mare Farm Cottage	05/06/2006	0.69	0.11	1.3	1.4	0.04	1.20	Nd	Nd	0.048
Val de la Mare Farm Cottage	22/02/2017	Nd/Nd <sub>12</sub>	0.10/0.10 <sub>12</sub>	1.2/1.2 <sub>12</sub>	Nd/Nd <sub>12</sub>	0.03/0.03 <sub>12</sub>	0.38/0.38 <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	0.14/0.12 <sub>12</sub>
Val de la Mare Farm Workshop	05/06/2006	Nd	0.06	0.24	Nd	Nd	0.08	Nd	Nd	Nd
Val de la Mare Farm Workshop	06/12/2006	0.044	0.081	0.38	Nd	0.010	0.23	Nd	Nd	0.029
Pump	12/03/2009	Nd	Nd	Nd	Nd	Nd	0.048	Nd	Nd	Nd
Pump	23/06/2009	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd
Pump	14/01/2010	Nd	Nd	0.034	Nd	Nd	0.068	Nd	Nd	Nd
Pump	28/08/2014	Nd	Nd	0.014	Nd	Nd	Nd	Nd	Nd	Nd
<b>Sampling Point Ravenscroft</b>										
Ravenscroft	07/04/1999	-	-	-	-	-	-	-	-	-
Ravenscroft	10/11/2005	-	-	-	-	-	1.50	-	-	-
Ravenscroft	05/06/2006	0.04	0.08	0.49	Nd	Nd	0.55	Nd	Nd	0.11
Ravenscroft	07/12/2006	0.14	0.21	1.4	Nd	0.05	1.20	Nd	Nd	0.09
<b>Sampling Point South View</b>										
Southview Farm	24/11/2005	0.94	1.00	1.90	-	-	0.91	-	-	-
Southview Farm	05/06/2006	0.04	0.11	0.46	0.23	0.01	0.13	-	-	nd
Southview Farm	07/12/2006	0.15	0.26	1.10	Nd	Nd	0.30	Nd	Nd	0.04
Southview Farm	21/05/2010	0.16	0.13	1.00	Nd	Nd	0.27	Nd	Nd	0.08
Southview Farm	13/06/2011	0.20	0.15	1.40	Nd	Nd	0.23	Nd	Nd	0.10
Southview Farm	15/08/2012	0.14	0.16	1.4	0.033	0.015	0.24	Nd	Nd	0.10
Southview Farm	05/03/2013	0.08	0.11	1.52	Nd	0.03	0.56	Nd	Nd	0.19
Southview Farm	22/02/2012	0.15	0.21	2	Nd	0.067	1.20	Nd	Nd	0.23
Southview Farm	21/05/2006	-	-	-	-	-	0.27	-	-	0.083
Southview Farm	16/04/2014	0.093	0.20	2.5	Nd	0.083	2.00	Nd	Nd	0.29
Southview Farm	15/03/2015	0.08	0.11	1.52	Nd	0.03	0.56	Nd	Nd	0.19
Southview Farm	21/02/2017	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd
Southview Farm	21/02/2017	Nd	0.11	2.1	Nd	0.04	1.6	Nd	Nd	0.20

<b>sampling Point Bethel House</b>	<b>Sampling date</b>	<b>PFBS</b>	<b>PFPS</b>	<b>PFHS</b>	<b>TDFOS</b>	<b>PFHpS</b>	<b>PFOS</b>	<b>TDFOXAS</b>	<b>TDFOPAS</b>	<b>PFOA</b>
Bethel House	06/04/1999	-	-	-	-	-	-	-	-	-
Bethel House	20/01/2000	0.62	0.91	1.77	-	-	0.95	-	-	-
Bethel House	19/04/2000	0.73	1.1	2.07	-	0.39	<b>2.50</b>	-	-	-
Bethel House	24/07/2000	0.88	0.90	1.69	-	-	<b>1.40</b>	-	-	-
Bethel House	01/11/2000	1.50	2.10	4.00	-	-	<b>2.50</b>	-	-	-
Bethel House	03/11/2000	1.10	1.70	3.30	-	-	<b>3.10</b>	-	-	-
Bethel House	22/04/2001	-	-	0.86	-	-	<b>1.30</b>	-	-	-
Bethel House	17/10/2001	-	-	1.50	-	-	<b>1.30</b>	-	-	-
Bethel House	04/04/2002	-	-	1.20	-	-	<b>1.70</b>	-	-	-
Bethel House	09/10/2002	-	-	0.23	-	-	0.61	-	-	-
Bethel House	15/10/2003	-	0.11	0.53	-	-	0.46	-	-	-
Bethel House	26/04/2004	0.82	0.93	3.10	-	-	0.58	-	-	-
Bethel House	26/10/2004	0.33	0.40	1.10	-	-	0.78	-	-	-
Bethel House	02/11/2004	-	-	-	-	-	<b>1.40</b>	-	-	-
Bethel House	05/06/2006	0.19	0.33	1.80	Nd	0.11	<b>1.10</b>	Nd	Nd	0.091
Bethel House	20/06/2006	0.11	0.33	1.30	Nd	0.11	<b>1.00</b>	Nd	Nd	0.16
Bethel House	04/07/2006	0.14	0.41	1.80	-	0.11	<b>1.10</b>	-	-	-
Bethel House	18/07/2006	0.12	0.33	1.30	Nd	0.10	<b>1.10</b>	Nd	Nd	0.22
Bethel House	21/05/2010	0.23	0.13	1.50	Nd	0.049	<b>1.10</b>	Nd	Nd	0.18
Bethel House	14/06/2011	0.22	0.18	2.00	Nd	0.06	<b>1.00</b>	Nd	Nd	0.19
Bethel House	20/02/2012	0.22/0.23 <sub>12</sub>	0.22/0.23 <sub>12</sub>	2.1/2.2 <sub>12</sub>	Nd/Nd <sub>12</sub>	0.063/0.075 <sub>12</sub>	0.92/0.94 <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	0.20/0.22 <sub>12</sub>
Bethel House	09/08/2012	0.19	0.18	1.8	Nd	0.054	0.76	Nd	Nd	0.16
Bethel House	05/03/2013	0.14	0.09	1.4	Nd	0.04	0.55	Nd	Nd	0.12
Bethel House	01/05/2014	0.15	0.18	2.2	Nd	0.062	<b>1.60</b>	Nd	Nd	0.16
Bethel House	02/06/2015	0.14	0.16	1.9	Nd	0.034	<b>1.00</b>	Nd	Nd	0.19
<b>Sampling Point Les Cotils</b>	<b>Sampling date</b>	<b>PFBS</b>	<b>PFPS</b>	<b>PFHS</b>	<b>TDFOS</b>	<b>PFHpS</b>	<b>PFOS</b>	<b>TDFOXAS</b>	<b>TDFOPAS</b>	<b>PFOA</b>
Les Cotils	06/04/1999	-	-	-	-	-	-	-	-	-
Les Cotils	20/01/2000	0.83	1.4	2.93	-	-	<b>1.20</b>	-	-	-
Les Cotils	20/04/2000	2.38	4.8	10.15	12.18	2.2	<b>60.00</b>	-	-	-
Les Cotils	09/06/2000	2.28	2.70	4.89	<0.84	0.33	<b>1.80</b>	-	-	-
Les Cotils	28/07/2000	2.33	2.9	5.26	-	0.39	<b>2.20</b>	-	-	-
Les Cotils	03/11/2000	1.70	2.20	4.00	-	0.23	<b>1.00</b>	-	-	-
Les Cotils	04/11/2000	2.70	4.40	11.00	-	0.84	<b>3.70</b>	-	-	-
Les Cotils	01/05/2001	-	2.10	2.30	-	0.84	<b>3.70</b>	-	-	-
Les Cotils	23/10/2001	1.70	2.10	3.60	-	0.44	<b>1.30</b>	-	-	-
Les Cotils	04/04/2002	0.89	0.78	2.60	-	0.61	<b>2.10</b>	-	-	-
Les Cotils	16/10/2002	-	-	0.61	-	-	<b>1.70</b>	-	-	-
Les Cotils	03/02/2003	1.20	2.30	4.40	-	-	<b>1.00</b>	-	-	-
Les Cotils	06/03/2003	1.20	2.10	3.80	-	0.61	<b>3.00</b>	-	-	-
Les Cotils	06/05/2003	1.20	2.40	5.20	0.52	0.40	<b>1.30</b>	-	-	-
Les Cotils	24/07/2003	4.70	9.10	19.00	-	0.55	<b>1.80</b>	-	-	-
Les Cotils	19/09/2003	4.90	7.20	14.00	0.76	1.50	<b>8.10</b>	-	-	-
Les Cotils	15/10/2003	0.38	0.85	3.20	0.11	0.81	<b>5.40</b>	-	-	-
Les Cotils	05/01/2004	0.26	0.55	1.90	-	0.48	<b>3.30</b>	-	-	-
Les Cotils	30/01/2004	7.90	11.00	16.00	2.60	0.26	<b>1.50</b>	-	-	-
Les Cotils	18/02/2004	2.90	3.30	7.90	0.74	0.99	<b>9.40</b>	-	-	-
Les Cotils	09/03/2004	2.20	3.90	7.60	0.95	0.95	<b>5.20</b>	-	-	-
Les Cotils	26/04/2004	3.40	0.83	15.00	0.71	0.95	<b>3.40</b>	-	-	-
Les Cotils	15/07/2004	2.50	6.50	14.00	-	0.94	<b>3.70</b>	-	-	-
Les Cotils	29/09/2004	4.30	7.00	15.00	0.64	1.70	<b>9.60</b>	-	-	-
Les Cotils	02/11/2004	0.97	1.50	4.00	-	1.40	<b>5.10</b>	-	-	-
Les Cotils	23/02/2005	6.00	5.60	14.00	0.84	1.40	<b>5.80</b>	-	-	-
Les Cotils	30/03/2005	4.90	12.00	18.00	-	2.20	<b>12.00</b>	-	-	-
Les Cotils	16/05/2005	2.90	4.00	6.30	2.50	1.60	<b>3.20</b>	-	-	-
Les Cotils	10/11/2005	12.00	19.00	44.00	-	11.00	<b>4.50</b>	-	-	-
Les Cotils	31/05/2006	1.30	2.70	11.00	0.68	0.91	<b>4.80</b>	Nd	Nd	3.5
Les Cotils	07/12/2006	1.80	3.70	15.00	0.49	1.10	<b>6.20</b>	Nd	Nd	0.98
Les Cotils	27/06/2007	1.60	2.90	14.00	0.86	0.75	<b>5.10</b>	Nd	Nd	0.98
Les Cotils	09/01/2008	4.4/5.0 <sub>12</sub>	19/23 <sub>12</sub>	30/34 <sub>12</sub>	1.5/1.6 <sub>12</sub>	1.0/1.1 <sub>12</sub>	<b>4.2/4.5<sub>12</sub></b>	Nd	Nd	3.50
Les Cotils	11/06/2008	1.20	4.50	14.00	1.60	1.40	<b>9.40</b>	Nd	Nd	0.83
Les Cotils	16/12/2008	1.40	0.88	8.30	Nd	0.52	<b>3.50</b>	Nd	Nd	0.43
Les Cotils	22/06/2009	5.2/4.8 <sub>12</sub>	2.1/2.1 <sub>12</sub>	8.7/8.2 <sub>12</sub>	Nd	0.7/0.75 <sub>12</sub>	<b>5.6/6.0<sub>12</sub></b>	Nd	Nd	0.83/0.85 <sub>12</sub>
Les Cotils	22/12/2009	-	-	-	-	-	<b>2.90</b>	-	-	0.39
Les Cotils	03/02/2011	-	-	-	-	-	<b>3.30</b>	-	-	0.46
Les Cotils	16/06/2011	-	-	-	-	-	<b>4.10</b>	-	-	1.1
Les Cotils	13/02/2012	1.5	1.5	8.9	0.15	0.4	<b>3.10</b>	Nd	Nd	0.7
Les Cotils	09/08/2012	1.2	1.4	8.8	0.12	0.37	<b>3.20</b>	Nd	Nd	0.66
Les Cotils	05/03/2013	0.77	0.71	4.93	0.08	0.17	<b>1.05</b>	Nd	Nd	0.34
Les Cotils	15/05/2014	1.2	1.2	9.4	0.45	0.44	<b>3.30</b>	Nd	Nd	0.73
Les Cotils	13/05/2015	1.0	1.3	8.3	0.12	0.29	<b>3.00</b>	Nd	Nd	0.59
Les Cotils	02/06/2016	0.8	0.62	13	0.48	0.57	<b>6.8</b>	Nd	Nd	0.68
<b>Sampling Point Le Guet</b>	<b>Sampling date</b>	<b>PFBS</b>	<b>PFPS</b>	<b>PFHS</b>	<b>TDFOS</b>	<b>PFHpS</b>	<b>PFOS</b>	<b>TDFOXAS</b>	<b>TDFOPAS</b>	<b>PFOA</b>
Le Guet	02/06/2015	0.45/0.54 <sub>12</sub>	0.72/0.88 <sub>12</sub>	7.1/8.5 <sub>12</sub>	0.49/0.61 <sub>12</sub>	0.46/0.55 <sub>12</sub>	<b>25/26<sub>12</sub></b>	Nd/Nd <sub>12</sub>	0.19/0.17 <sub>12</sub>	0.44/0.58 <sub>12</sub>
Le Guet	23/02/2016	0.81	1.4	10	0.96	0.66	<b>33</b>	Nd	0.23	0.67
Le Guet	30/06/2016	0.62	0.78	11	0.93	0.37	<b>29</b>	Nd	0.34	0.63
<b>Sampling Point Camelia Cottage</b>	<b>Sampling date</b>	<b>PFBS</b>	<b>PFPS</b>	<b>PFHS</b>	<b>TDFOS</b>	<b>PFHpS</b>	<b>PFOS</b>	<b>TDFOXAS</b>	<b>TDFOPAS</b>	<b>PFOA</b>
Camelia Cottage	25/05/2010	0.19	0.14	1.3	Nd	0.032	1.6	Nd	Nd	0.094
Camelia Cottage	09/03/2012	0.17	0.2	2	Nd	0.058	1.9	Nd	Nd	0.16
Camelia Cottage	17/04/2014	0.21	0.27	3.0	Nd	0.080	4.2	Nd	Nd	0.17
Camelia Cottage	26/05/2015	0.11	0.17	1.7	Nd	0.035	2.2	Nd	Nd	0.13
<b>Sampling Point Chateau du Port</b>	<b>Sampling date</b>	<b>PFBS</b>	<b>PFPS</b>	<b>PFHS</b>	<b>TDFOS</b>	<b>PFHpS</b>	<b>PFOS</b>	<b>TDFOXAS</b>	<b>TDFOPAS</b>	<b>PFOA</b>
Chateau du Port	06/04/1999	-	-	-	-	-	-	-	-	-
Chateau du Port	05/05/1999	-	-	-	-	-	-	-	-	-
Chateau du Port	11/05/1999	-	-	5.24	-	-	<b>5.03</b>	-	-	-
Chateau du Port	18/05/1999	-	-	-	-	-	-	-	-	-
Chateau du Port	25/05/1999	-	-	-	-	-	-	-	-	-
Chateau du Port	01/06/1999	-	-	-	-	-	-	-	-	-
Chateau du Port	08/06/1999	-	-	-	-	-	-	-	-	-
Chateau du Port	14/06/1999	0.72	-	2.82	-	-	<b>2.79</b>	-	-	-
Chateau du Port	22/06/1999	1.56	-	5.24	-	-	<b>3.64</b>	-	-	-
Chateau du Port	07/01/2000	-	-	2.97	-	-	<b>3.40</b>	-	-	-
Chateau du Port	25/04/2000	2.69	3.5	5.64	3.36	0.93	<b>5.40</b>	-	-	-
Chateau du Port	29/07/2000	3.73	5.1	6.02	4.62	1.4	<b>8.70</b>	-	-	-
Chateau du Port	02/11/2000	1.8	1.6	2.7	-	-	<b>2.60</b>	-	-	-
Chateau du Port	22/04/2001	1.6	2.8	2.00	-	-	<b>3.50</b>	-	-	-
Chateau du Port	23/10/2001	-	2.60	2.70	-	-	<b>4.50</b>	-	-	-
Chateau du Port	04/04/2002	1.00	1.80	2.30	1.10	-	<b>2.50</b>	-	-	-
Chateau du Port	05/10/2002	-	-	0.65	-	-	<b>1.90</b>	-	-	-
Chateau du Port	07/05/2003	0.76	1.40	3.50	0.28	0.61	<b>2.70</b>	-	-	-
Chateau du Port	15/10/2003	0.24	0.52	1.70	-	0.31	<b>4.90</b>	-	-	-
Chateau du Port	21/04/2004	1.60	2.20	7.40	-	0.19	<b>5.10</b>	-	-	-
Chateau du Port	27/10/2004	0.75	1.10	3.00	-	0.30	<b>4.60</b>	-	-	-
Chateau du Port	05/06/2006	0.66	1.20	5.50	0.32	0.38	<b>6.80</b>	Nd	Nd	0.36
Chateau du Port	26/06/2006	0.52	1.60	5.00	0.34	0.47	<b>5.50</b>	-	-	-
Chateau du Port	10/07/2006	0.20	0.70	2.20	4.30	0.22	<b>2.70</b>	-	-	-
Chateau du Port	18/07/2006	0.48	1.40	4.60	0.21	0.50	<b>6.90</b>	Nd	Nd	0.44
Chateau du Port	20/06/2011	1.00	0.84	5.70	0.15	0.24	<b>4.50</b>	Nd	Nd	0.42
Chateau du Port	21/02/2012	0.89	1.0	6.6	0.093	0.28	<b>5.00</b>	Nd	Nd	0.38
Chateau du Port	09/08/2012	0.52	0.71	4.8	0.071	0.19	<b>3.90</b>	Nd	Nd	0.31
Chateau du Port	05/03/2013	0.53	0.54	3.9	0.06	0.13	<b>2.34</b>	Nd	Nd	0.23
Chateau du Port	15/04/2014	0.53	0.55	4.9	0.14	0.18	<b>4.60</b>	Nd	Nd	0.34
Chateau du Port	27/05/2015	0.43	0.54	4.5	0.073	0.14	<b>4.30</b>	Nd	Nd	0.20

Sampling Point Bethesda Methodist Church	Sampling date	PFBS	PFPS	PFHS	TDFOS	PFHpS	PFOS	TDFOXAS	TDFOPAS	PFOA
Bethesda Church Nursery	05/06/2006	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd
Bethesda Church Nursery	19/06/2006	Nd	Nd	Nd	Nd	Nd	0.01	Nd	Nd	nd
Bethesda Church Nursery	25/09/2006	0.03	0.03	0.02	Nd	Nd	0.19	Nd	Nd	Nd
Bethesda Church Nursery	06/12/2006	Nd	Nd	0.03	Nd	Nd	0.15	Nd	Nd	Nd
Bethesda Church Nursery	16/12/2008	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd
Bethesda Church	12/03/2012	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd
Bethesda Church	09/08/2012	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd
Bethesda Church	04/03/2012	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd
Bethesda Church Cottage	16/04/2014	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd
Bethesda Church	12/05/2015	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd	Nd
Sampling Point Gracedieu	Sampling date	PFBS	PFPS	PFHS	TDFOS	PFHpS	PFOS	TDFOXAS	TDFOPAS	PFOA
Gracedieu	30/06/2016	0.47	0.37	5.3	Nd	0.19	5.3	Nd	Nd	0.24
Sampling Point La Piece Michel	Sampling date	PFBS	PFPS	PFHS	TDFOS	PFHpS	PFOS	TDFOXAS	TDFOPAS	PFOA
La Piece Michel	24/05/2010	9.1	6.8	44	0.61	3.7	29	0.27	0.96	3.4
La Piece Michel	24/01/2011	-	-	-	-	-	34	-	-	2.7
La Piece Michel	16/06/2011	7.7	7	45	3.4	2.5	28	0.18	0.8	4.9
La Piece Michel	20/02/2012	7.0	7.4	43	2.4	3.0	29	0.11	0.96	3.8
La Piece Michel	09/08/2012	5.6	7.0	39	1.7	2.5	23	0.046	0.51	3.5
La Piece Michel	05/03/2013	5.2	5.6	33	2.1	2	15.00	0.04	0.73	2.70
La Piece Michel	17/04/2014	6.9	7.7	55	7.6	4.4	40	0.85	3.2	5
La Piece Michel	01/06/2015	6.0	7.2	46	2.0	3.0	32	0.094	0.66	4.2
La Piece Michel	02/06/2016	7.3	4.6	51.0	3.4	2.5	31	Nd	Nd	3.6
Sampling Point Le Clos Luce	Sampling date	PFBS	PFPS	PFHS	TDFOS	PFHpS	PFOS	TDFOXAS	TDFOPAS	PFOA
Le Clos Luce	23/02/2016	Nd/Nd <sub>12</sub>	0.019/0.019 <sub>12</sub>	0.28/0.27 <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	0.46/0.46 <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>
Sampling Point El Tico Beach Café & Flat	Sampling date	PFBS	PFPS	PFHS	TDFOS	PFHpS	PFOS	TDFOXAS	TDFOPAS	PFOA
El Tico Café Kitchen	06/04/1999	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	not examined
El Tico Café Kitchen	30/04/1999	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	not examined
El Tico Café Kitchen	07/05/1999	<LOD	<LOD	0.93	<LOD	<LOD	0.47	<LOD	<LOD	not examined
El Tico Café Kitchen	14/05/1999	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	not examined
El Tico Café Kitchen	21/05/1999	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	not examined
El Tico Café Kitchen	28/05/1999	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	not examined
El Tico Café Kitchen	04/06/1999	<LOD	<LOD	0.70	<LOD	<LOD	0.2	<LOD	<LOD	not examined
El Tico Café Kitchen	16/06/1999	<LOD	<LOD	0.73	<LOD	<LOD	0.43	<LOD	<LOD	not examined
El Tico Café Kitchen	07/01/2000	<LOD	<LOD	0.53	<LOD	<LOD	0.38	<LOD	<LOD	not examined
El Tico Café Kitchen	18/01/2000	<LOD	<LOD	0.68	<LOD	<LOD	0.28	<LOD	<LOD	not examined
El Tico Café Kitchen	14/04/2000	<LOD	0.56	1.02	<LOD	<LOD	0.35	<LOD	<LOD	not examined
El Tico Café Kitchen	02/11/2000	<LOD	<LOD	1.90	<LOD	<LOD	1.50	<LOD	<LOD	not examined
El Tico Café Kitchen	02/11/2000	<LOD	<LOD	1.10	<LOD	<LOD	0.48	<LOD	<LOD	not examined
El Tico Café Kitchen	13/04/2001	<LOD	<LOD	0.56	<LOD	<LOD	0.85	<LOD	<LOD	not examined
El Tico Café Kitchen	15/10/2001	<LOD	<LOD	0.60	<LOD	<LOD	0.66	<LOD	<LOD	not examined
El Tico Café Kitchen	02/04/2002	<LOD	<LOD	0.32	<LOD	<LOD	2.10	<LOD	<LOD	not examined
El Tico Café Kitchen	05/10/2002	<LOD	<LOD	0.12	<LOD	<LOD	0.52	<LOD	<LOD	not examined
El Tico Café Kitchen	20/04/2003	<0.58	<0.58	1.40	<0.53	<0.58	1.20	<0.53	<0.53	not examined
El Tico Café Kitchen	15/10/2003	<0.58	<0.58	0.19	<0.53	<0.58	0.89	<0.53	<0.53	not examined
El Tico Café Kitchen	21/04/2004	<0.58	0.27	0.89	<0.53	<0.58	0.68	<0.53	<0.53	not examined
El Tico Café Kitchen	25/10/2004	<0.58	0.17	0.43	<0.53	<0.58	0.68	<0.53	<0.53	not examined
El Tico Café Kitchen	12/06/2006	0.05	0.09	0.60	<0.53	0.04	0.60	<0.53	<0.53	<0.03
El Tico Café Kitchen	01/08/2006	0.03	0.08	0.33	Nd	0.04	0.80	Nd	Nd	0.10
El Tico Café Kitchen	04/09/2006	0.03	0.08	0.37	0.20	0.07	0.73	Nd	Nd	0.09
El Tico Bunker Borehole	03/02/2016	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	0.82/0.98 <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	1.34/1.51 <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	0.068/0.137 <sub>12</sub>
El Tico Bunker Borehole	08/03/2016	0.027/0.028 <sub>12</sub>	0.070/0.065 <sub>12</sub>	0.70/0.63 <sub>12</sub>	Nd/Nd <sub>12</sub>	0.017/0.016 <sub>12</sub>	1.20/1.1 <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	0.069/0.074 <sub>12</sub>
El Tico Bunker Borehole	08/07/2016	Nd/Nd <sub>12</sub>	0.045/0.047 <sub>12</sub>	0.72/0.69 <sub>12</sub>	Nd/Nd <sub>12</sub>	0.021/0.018 <sub>12</sub>	1.3/1.3 <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	0.088/0.077 <sub>12</sub>
Sampling Point Simon Sand Pit Office	Sampling date	PFBS	PFPS	PFHS	TDFOS	PFHpS	PFOS	TDFOXAS	TDFOPAS	PFOA
Simon Sand Pit Office	16/06/1999	-	-	0.55	-	-	nd	-	-	not examined
Simon Sand Pit Office	07/01/2000	-	-	0.38	-	-	nd	-	-	not examined
Simon Sand Pit Office	19/04/2000	0.23	0.36	0.90	-	-	0.37	-	-	not examined
Simon Sand Pit Office	19/07/2000	-	-	1.32	-	-	<0.20	-	-	not examined
Simon Sand Pit Office	27/10/2000	-	-	0.64	-	-	<1.0	-	-	not examined
Simon Sand Pit Office	07/11/2000	-	-	1.10	-	-	0.51	-	-	not examined
Simon Sand Pit Office	17/04/2001	-	-	0.42	-	-	0.72	-	-	not examined
Simon Sand Pit Office	23/10/2001	-	-	<0.4	-	-	<0.4	-	-	not examined
Simon Sand Pit Office	02/04/2002	-	-	0.26	-	-	0.26	-	-	not examined
Simon Sand Pit Office	09/10/2002	-	-	<0.08	-	-	0.34	-	-	not examined
Simon Sand Pit Office	15/10/2002	-	-	0.09	-	-	0.47	-	-	not examined
Simon Sand Pit Office	29/04/2003	0.21	<0.58	0.65	<0.53	<0.58	<0.2	<0.53	<0.53	not examined
Simon Sand Pit Office	11/11/2003	<0.58	<0.58	0.23	<0.53	<0.58	0.26	<0.53	<0.53	not examined
Simon Sand Pit Office	11/11/2003	<0.58	0.23	<0.08	<0.53	0.26	<0.2	<0.53	<0.53	not examined
Simon Sand Pit Office	21/04/2004	<0.58	0.12	0.75	<0.53	<0.58	0.92	<0.53	<0.53	not examined
Simon Sand Pit Office	25/10/2004	0.12	0.12	0.46	<0.53	<0.58	0.24	<0.53	<0.53	not examined
Simon Sand Pit Office	05/06/2006	0.05	0.11	0.64	<0.53	0.05	0.30	<0.53	<0.53	0.09
Simon Sand Pit Office	20/06/2006	0.04	0.11	0.39	<0.53	0.06	0.18	<0.53	<0.53	0.05
Simon Sand Pit Office	04/07/2006	0.04	0.10	0.52	<0.53	0.06	0.26	<0.53	<0.53	<0.03
Simon Sand Pit Office	18/07/2006	0.04	0.11	0.55	<0.53	0.08	0.29	<0.53	<0.53	0.17
Simon Sand Pit Office	27/05/2015	Nd	0.034	0.37	nd	Nd	0.65	Nd	Nd	0.073
Simon Sand Pit Office	02/06/2016	Nd	Nd	0.14	Nd	Nd	0.74	Nd	Nd	Nd
Sampling Point Watersplash	Sampling date	PFBS	PFPS	PFHS	TDFOS	PFHpS	PFOS	TDFOXAS	TDFOPAS	PFOA
Watersplash RH source	06/04/1999	-	-	-	-	-	-	-	-	-
Watersplash RH source	05/05/1999	-	-	-	-	-	-	-	-	-
Watersplash RH source	11/05/1999	-	-	1.8	-	-	0.22	-	-	-
Watersplash RH source	19/05/1999	-	-	-	-	-	-	-	-	-
Watersplash RH source	25/05/1999	-	-	-	-	-	-	-	-	-
Watersplash RH source	01/06/1999	-	-	-	-	-	-	-	-	-
Watersplash RH source	08/06/1999	-	-	-	-	-	-	-	-	-
Watersplash RH source	15/06/1999	0.52	-	1.80	-	-	0.43	-	-	-
Watersplash RH source	22/06/1999	-	-	9.02	-	-	1.86	-	-	-
Watersplash RH source	08/12/1999	-	-	-	-	-	0.49	-	-	-
Watersplash RH source	07/01/2000	-	-	1.73	-	-	1.10	-	-	-
Watersplash RH source	19/01/2000	0.78	1.30	2.41	-	-	0.82	-	-	-
Watersplash RH source	18/04/2000	1.04	1.70	2.67	<0.84	0.46	1.00	-	-	-
Watersplash RH source	19/07/2000	0.57	1.30	1.65	-	-	0.56	-	-	-
Watersplash RH source	01/11/2000	-	-	2.60	-	-	1.10	-	-	-
Watersplash RH source	07/11/2000	1.40	2.20	3.90	-	0.63	2.00	-	-	-
Watersplash RH source	21/04/2001	1.10	1.60	1.00	-	0.63	2.00	-	-	-
Watersplash RH source	15/10/2001	-	-	2.10	-	-	1.30	-	-	-
Watersplash RH source	12/04/2002	-	1.10	1.60	-	-	1.50	-	-	-
Watersplash RH source	09/10/2002	-	-	0.30	-	-	0.52	-	-	-
Watersplash RH source	29/04/2003	0.69	1.80	2.70	-	-	0.52	-	-	-
Watersplash RH source	16/10/2003	0.09	0.24	0.43	-	-	1.30	-	-	-
Watersplash RH source	26/04/2004	0.69	0.84	1.70	-	-	0.94	-	-	-
Watersplash RH source	27/10/2004	0.19	0.41	0.57	-	-	0.48	-	-	-
Watersplash RH source	28/10/2004	-	-	-	-	-	0.48	-	-	-
Watersplash RH source	13/06/2006	0.12	0.32	0.74	Nd	0.11	0.58	Nd	Nd	Nd
Watersplash RH source	25/07/2006	0.09	0.27	0.66	Nd	0.08	0.40	Nd	Nd	0.14
Watersplash RH source	27/06/2006	0.15	0.15	1.40	Nd	0.02	0.45	Nd	Nd	0.069
Watersplash RH source	11/07/2006	-	-	-	-	-	0.50	-	-	-
Watersplash RH source	27/04/2006	-	-	-	-	-	0.40	-	-	0.14
Watersplash RH source	12/07/2016	0.15	0.15	1.40	Nd	0.02	0.45	Nd	Nd	0.069
Watersplash LH Source	07/04/1999	-	-	-	-	-	-	-	-	-
Watersplash LH Source	30/04/1999	-	-	-	-	-	-	-	-	-
Watersplash LH Source	07/05/1999	-	-	1.57	-	-	nd	-	-	-
Watersplash LH Source	14/05/1999	-	-	-	-	-	-	-	-	-
Watersplash LH Source	21/05/1999	0.68	-	2.56	-	-	1.16	-	-	-
Watersplash LH Source	28/05/1999	0.56	-	2.15	-	-	Nd	-	-	-

Watersplash LH Source	04/06/1999	0.56	-	2.24	-	-	0.39	-	-	-
Watersplash LH Source	11/06/1999	0.40	-	1.63	-	-	0.43	-	-	-
Watersplash LH Source	25/01/2000	0.48	0.75	1.39	-	-	0.65	-	-	-
Watersplash LH Source	14/04/2000	1.19	2.00	3.46	1.64	0.67	1.80	-	-	-
Watersplash LH Source	24/07/2000	1.50	1.30	2.63	-	-	1.10	-	-	-
Watersplash LH Source	27/10/2000	1.20	1.60	2.80	-	0.42	0.83	-	-	-
Watersplash LH Source	10/11/2000	1.50	2.30	4.20	-	-	2.20	-	-	-
Watersplash LH Source	17/04/2001	1.10	1.60	1.20	-	-	2.20	-	-	-
Watersplash LH Source	17/10/2001	-	2.20	2.60	-	-	1.00	-	-	-
Watersplash LH Source	05/04/2002	-	1.00	1.50	-	-	1.90	-	-	-
Watersplash LH Source	09/10/2002	-	-	0.30	-	-	5.00	-	-	-
Watersplash LH Source	07/05/2003	0.33	0.69	1.00	0.45	-	0.56	-	-	-
Watersplash LH Source	04/11/2003	0.10	0.20	0.60	-	0.13	0.62	-	-	-
Watersplash LH Source	21/04/2004	0.56	1.30	1.50	-	-	0.68	-	-	-
Watersplash LH Source	25/10/2004	0.19	0.23	0.71	-	0.11	0.07	-	-	-
Watersplash LH Source	04/11/2004	0.10	0.20	0.60	-	-	0.81	-	-	-
Watersplash LH Source	05/06/2006	0.14	0.17	0.76	Nd	0.06	0.34	Nd	Nd	Nd
Watersplash LH Source	20/06/2006	0.06	0.14	0.35	0.09	0.04	0.29	Nd	Nd	0.06
Watersplash LH Source	04/07/2006	0.1	0.26	0.54	0.26	0.07	0.25	-	-	-
Watersplash LH Source	18/07/2006	0.09	0.20	0.58	0.13	0.07	0.23	Nd	Nd	0.06
Watersplash LH Source	21/03/2016	Nd/Nd <sub>12</sub>	0.20/0.18 <sub>12</sub>	1.2/1.0 <sub>12</sub>	Nd/Nd <sub>12</sub>	0.026/0.022 <sub>12</sub>	0.17/0.15 <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	0.074/0.079 <sub>12</sub>
Watersplash LH Source	06/07/2016	0.17	0.15	1.6	Nd	0.023	0.47	Nd	Nd	0.093
<b>Sampling Point Pres d'Etang</b>	<b>Sampling date</b>	<b>PFBS</b>	<b>PFPS</b>	<b>PFHS</b>	<b>TDFOS</b>	<b>PFHpS</b>	<b>PFOS</b>	<b>TDFOXAS</b>	<b>TDFOPAS</b>	<b>PFOA</b>
Pres d'Etang	15/02/1999	-	-	-	-	-	-	-	-	-
Pres d'Etang	09/06/1999	-	-	-	-	-	nd	-	-	-
Pres d'Etang	15/06/1999	-	-	-	-	-	nd	-	-	-
Pres d'Etang	22/06/1999	-	-	-	-	-	nd	-	-	-
Pres d'Etang	30/06/1999	-	-	-	-	-	nd	-	-	-
Pres d'Etang	31/03/2006	0.05	0.17	0.63	0.53	0.05	2.16	0.53	0.53	-
Pres d'Etang	24/04/2006	-	-	-	-	-	nd	-	-	nd
Pres d'Etang	12/06/2006	<0.58	<0.58	0.05	<0.53	<0.58	0.08	<0.53	<0.53	0.03
Pres d'Etang	26/06/2006	<0.58	<0.58	0.03	0.21	<0.58	0.01	<0.53	<0.53	0.03
Pres d'Etang	10/07/2006	<0.58	<0.58	0.04	<0.53	<0.58	0.04	<0.53	<0.53	0.03
Pres d'Etang	24/07/2006	<0.58	<0.58	0.04	Nd	0.16	<0.58	0.01	<0.53	0.03
<b>Sampling Point Les Sablons</b>	<b>Sampling date</b>	<b>PFBS</b>	<b>PFPS</b>	<b>PFHS</b>	<b>TDFOS</b>	<b>PFHpS</b>	<b>PFOS</b>	<b>TDFOXAS</b>	<b>TDFOPAS</b>	<b>PFOA</b>
Les Sablons	22/02/2012	0.020/0.017 <sub>12</sub>	0.010/0.010 <sub>12</sub>	0.053/0.049 <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>	Nd/Nd <sub>12</sub>
Les Sablons	14/08/2012	0.025	Nd	0.035	Nd	Nd	Nd	Nd	Nd	Nd
Les Sablons	05/03/2013	0.02	Nd	0.03	Nd	Nd	Nd	Nd	Nd	Nd
Les Sablons	01/05/2014	Nd	0.016	0.076	Nd	Nd	Nd	Nd	Nd	Nd
<b>Monitoring Sites</b>										
<b>Sampling Point Simon Sand Field Monitoring Sites (No longer exists)</b>	<b>Sampling date</b>	<b>PFBS</b>	<b>PFPS</b>	<b>PFHS</b>	<b>TDFOS</b>	<b>PFHpS</b>	<b>PFOS</b>	<b>TDFOXAS</b>	<b>TDFOPAS</b>	<b>PFOA</b>
Simon Sand Field	11/06/1999	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	not examined
Simon Sand Field	18/01/2000	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	not examined
Simon Sand Field	18/04/2000	<LOD	<LOD	0.08	<LOD	<LOD	0.2	<LOD	<LOD	not examined
Simon Sand Field	19/07/2000	<LOD	<LOD	0.08	<LOD	<LOD	0.2	<LOD	<LOD	not examined
Simon Sand Field	27/10/2000	<LOD	<LOD	0.26	<LOD	<LOD	0.5	<LOD	<LOD	not examined
Simon Sand Field	03/11/2000	<LOD	<LOD	<0.40	<LOD	<LOD	0.95	<LOD	<LOD	not examined
Simon Sand Field	17/04/2001	<LOD	<LOD	<0.08	<LOD	<LOD	0.6	<LOD	<LOD	not examined
Simon Sand Field	17/10/2001	<LOD	<LOD	<0.40	<LOD	<LOD	<0.2	<LOD	<LOD	not examined
Simon Sand Field	03/04/2002	<LOD	<LOD	0.51	<LOD	<LOD	1.2	<LOD	<LOD	not examined
Simon Sand Field	14/10/2002	<LOD	<LOD	<0.58	<LOD	<LOD	<0.2	<LOD	<LOD	not examined
Simon Sand Field	29/04/2003	<0.58	<0.58	1.1	<0.53	<0.58	1.4	<0.53	<0.53	not examined
Simon Sand Field	15/10/2003	0.08	0.08	1.15	<0.53	<0.58	0.47	<0.53	<0.53	not examined
Simon Sand Field	21/04/2004	0.26	0.31	1.1	<0.53	<0.58	0.35	<0.53	<0.53	not examined
Simon Sand Field	26/10/2004	<0.58	<0.58	0.31	<0.53	<0.58	0.36	<0.53	<0.53	not examined
<b>Sampling Point Simon Sand Field Monitoring Sites (No longer exists)</b>	<b>Sampling date</b>	<b>PFBS</b>	<b>PFPS</b>	<b>PFHS</b>	<b>TDFOS</b>	<b>PFHpS</b>	<b>PFOS</b>	<b>TDFOXAS</b>	<b>TDFOPAS</b>	<b>PFOA</b>
Simon Sand Field	11/06/1999	<LOD	<LOD	0.84	<LOD	<LOD	0.56	<LOD	<LOD	not examined
Simon Sand Field	18/01/2000	<LOD	<LOD	0.94	<LOD	<LOD	0.58	<LOD	<LOD	not examined
Simon Sand Field	18/04/2000	<LOD	<LOD	1.5	<LOD	<LOD	1.00	<LOD	<LOD	not examined
Simon Sand Field	19/07/2000	<LOD	<LOD	2.82	<LOD	<LOD	3.00	<LOD	<LOD	not examined
Simon Sand Field	27/10/2000	<LOD	<LOD	1.60	<LOD	<LOD	1.40	<LOD	<LOD	not examined
Simon Sand Field	04/11/2000	<LOD	<LOD	1.60	<LOD	<LOD	2.00	<LOD	<LOD	not examined
Simon Sand Field	17/04/2001	<LOD	<LOD	0.65	<LOD	<LOD	0.85	<LOD	<LOD	not examined
Simon Sand Field	17/10/2001	<LOD	<LOD	3.90	<LOD	<LOD	4.80	<LOD	<LOD	not examined
Simon Sand Field	03/04/2002	<LOD	<LOD	0.54	<LOD	<LOD	1.50	<LOD	<LOD	not examined
Simon Sand Field	14/10/2002	<LOD	<LOD	0.13	<LOD	<LOD	0.78	<LOD	<LOD	not examined
Simon Sand Field	29/04/2003	<0.58	<0.58	1.10	<0.53	<0.58	1.80	<0.53	<0.53	not examined
Simon Sand Field	15/10/2003	<0.58	<0.58	0.29	<0.53	<0.58	1.10	<0.53	<0.53	not examined
Simon Sand Field	21/04/2004	<0.58	<0.58	1.30	0.88	<0.58	1.20	<0.53	<0.53	not examined
Simon Sand Field	26/10/2004	<0.58	0.13	0.57	<0.53	<0.58	1.20	<0.53	<0.53	not examined
<b>Sampling Point Simon Sand Pond Monitoring Sites</b>	<b>Sampling date</b>	<b>PFBS</b>	<b>PFPS</b>	<b>PFHS</b>	<b>TDFOS</b>	<b>PFHpS</b>	<b>PFOS</b>	<b>TDFOXAS</b>	<b>TDFOPAS</b>	<b>PFOA</b>
Simon Sand Pond	17/08/1999	<LOD	<LOD	1.22	<LOD	<LOD	0.85	<0.85	<LOD	not examined
Simon Sand Pond	21/01/2000	<LOD	<LOD	0.79	<LOD	<LOD	0.57	<0.86	<LOD	not examined
Simon Sand Pond	19/04/2000	<LOD	<LOD	1.09	<LOD	<LOD	0.55	<0.87	<LOD	not examined
Simon Sand Pond	27/07/2000	<LOD	<LOD	1.05	<LOD	<LOD	6.8	<0.88	<LOD	not examined
Simon Sand Pond	27/10/2000	<LOD	<LOD	0.75	<LOD	<LOD	0.26	<0.89	<LOD	not examined
Simon Sand Pond	07/11/2000	<LOD	<LOD	2.00	<LOD	<LOD	1.70	<0.90	<LOD	not examined
Simon Sand Pond	15/10/2001	<LOD	<LOD	0.47	<LOD	<LOD	0.53	<0.91	<LOD	not examined
Simon Sand Pond	02/04/2002	<LOD	<LOD	0.46	<LOD	<LOD	1.20	<0.92	<LOD	not examined
Simon Sand Pond	29/04/2003	<0.58	<0.58	0.71	<0.53	<0.58	1.10	<0.53	<0.53	not examined
Simon Sand Pond	07/06/2006	0.04	0.09	0.73	0.22	0.04	1.00	Nd	Nd	0.09
Simon Sand Pond	07/06/2006	0.06	0.12	0.82	0.18	0.04	0.54	Nd	Nd	0.16
Simon Sand Pond	07/06/2006	0.04	0.14	0.94	Nd	0.07	2.5	Nd	Nd	0.11
Simon Sand Pond	07/06/2006	0.06	0.13	0.86	Nd	0.07	0.85	Nd	Nd	0.15
Simon Sand Pond	07/06/2006	0.04	0.14	0.94	<0.53	0.07	2.5	<0.53	<0.53	0.11
<b>Sampling Point Ditch Bethel House Monitoring Sites</b>	<b>Sampling date</b>	<b>PFBS</b>	<b>PFPS</b>	<b>PFHS</b>	<b>TDFOS</b>	<b>PFHpS</b>	<b>PFOS</b>	<b>TDFOXAS</b>	<b>TDFOPAS</b>	<b>PFOA</b>
Ditch Bethel House	18/05/1999	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	<LOD	not examined
Ditch Bethel House	20/01/2000	<LOD	1.1	1.54	2.82	<LOD	2.00	<LOD	<LOD	not examined
Ditch Bethel House	19/04/2000	0.41	0.78	1.43	5.04	0.37	3.00	<LOD	<LOD	not examined
Ditch Bethel House	24/07/2000	<LOD	<LOD	1.53	<LOD	<LOD	3.10	<LOD	<LOD	not examined
Ditch Bethel House	01/11/2000	<LOD	<LOD	2.80	<LOD	<LOD	7.40	<LOD	<LOD	not examined
Ditch Bethel House	03/11/2000	<LOD	<LOD	2.50	<LOD	<LOD	6.00	<LOD	<LOD	not examined
Ditch Bethel House	21/04/2001	1.10	2.40	1.40	<LOD	<LOD	12.00	<LOD	<LOD	not examined
Ditch Bethel House	04/04/2002	<LOD	<LOD	1.80	<LOD	<LOD	5.40	<LOD	<LOD	not examined
Ditch Bethel House	18/10/2002	<LOD	<LOD	0.40	<LOD	<LOD	1.90	<LOD	<LOD	not examined
Ditch Bethel House	29/04/2003	0.50	1.80	4.20	<0.53	0.90	7.40	<0.53	<0.53	not examined
<b>Sampling Point Car Park El Tico Monitoring Sites</b>	<b>Sampling date</b>	<b>PFBS</b>	<b>PFPS</b>	<b>PFHS</b>	<b>TDFOS</b>	<b>PFHpS</b>	<b>PFOS</b>	<b>TDFOXAS</b>	<b>TDFOPAS</b>	<b>PFOA</b>
El Tico Beach Car Park	11/06/1999	<LOD	<LOD	0.44	<LOD	<LOD	0.48	<LOD	<LOD	not examined
El Tico Beach Car Park	18/01/2000	<LOD	<LOD	<0.15	<LOD	<LOD	<0.4	<LOD	<LOD	not examined
El Tico Beach Car Park	18/04/2000	<LOD	<LOD	0.86	<LOD	<LOD	0.55	<LOD	<LOD	not examined
El Tico Beach Car Park	19/07/2000	<LOD	<LOD	<0.08	<LOD	<LOD	1.10	<LOD	<LOD	not examined
El Tico Beach Car Park	02/11/2000	<LOD	<LOD	0.40	<LOD	<LOD	1.20	<LOD	<LOD	not examined
El Tico Beach Car Park	02/11/2000	<LOD	<LOD	<0.08	<LOD	<LOD	0.49	<LOD	<LOD	not examined
El Tico Beach Car Park	17/04/2001	<LOD	<LOD	<0.08	<0.08	<LOD	0.32	<LOD	<LOD	not examined
El Tico Beach Car Park	16/10/2001	<LOD	<LOD	0.84	<LOD	<LOD	0.70	<LOD	<LOD	not examined
El Tico Beach Car Park	23/10/2001	<LOD	<LOD	<0.08	<LOD	<LOD	<0.2	<LOD	<LOD	not examined
El Tico Beach Car Park	03/04/2002	<LOD	<LOD	0.12	<LOD	<LOD	0.27	<LOD	<LOD	not examined
El Tico Beach Car Park	06/10/2002	<LOD	<LOD	0.28	<LOD	<LOD	0.43	<LOD	<LOD	not examined
El Tico Beach Car Park	14/10/2003	<0.58	<0.58	<0.08	<0.53	<0.58	0.28	<0.53	<0.53	not examined
El Tico Beach Car Park	21/04/2004	<0.58	<0.58	0.14	<0.53	<0.58	<0.2	<0.53	<0.53	not examined
El Tico Beach Car Park	25/10/2004	<0.58	<0.58	<0.08	<0.53	<0.58	<0.2	<0.53	<0.53	not examined
El Tico	12/06/2006	0.05	0.09	0.60	Nd	0.04	0.60	Nd	Nd	Nd
El Tico	01/08/2006	0.03	0.08	0.33	Nd	0.04	0.80	Nd	Nd	0.10
El Tico	04/08/2006	0.03	0.08	0.37	0.20	0.07	0.73	Nd	Nd	0.09

El Tico Sea Wall	28/06/2007	Nd	Nd	0.052	Nd	Nd	Nd	Nd	0.25	Nd
Sampling Point La Braye Monitoring Sites	Sampling date	PFBS	PFPS	PFHS	TDFOS	PFHpS	PFOS	TDFOXAS	TDFOPAS	PFOA
La Bray Disused Borehole	09/04/2001	<LOD	<LOD	<0.08	<LOD	<LOD	<0.2	<LOD	<LOD	not examined
La Braye Public WC Well	09/04/2001	<LOD	<LOD	<0.08	<LOD	<LOD	<0.2	<LOD	<LOD	not examined
Sampling Point Fire Training Ground1	Sampling date	PFBS	PFPS	PFHS	TDFOS	PFHpS	PFOS	TDFOXAS	TDFOPAS	PFOA
FTG1	23/02/2012	4	4.9	42	3.8	3.2	41	0.07	0.65	4.1
FTG1	15/08/2012	2.9	3.7	29	1.5	2.5	31	Nd	0.36	2.8
FTG1	06/03/2013	13.86	15.43	97.74	12.28	13.27	91.15	0.34	3.86	8.69
FTG1	17/09/2015	25	27	200.00	14	21	290.00	0.82	3.5	18
Sampling Point Fire Training Ground3	Sampling date	PFBS	PFPS	PFHS	TDFOS	PFHpS	PFOS	TDFOXAS	TDFOPAS	PFOA
FTG3	23/02/2012	3.6	5.7	63.00	3.3	5.2	90.00	0.072	1.2	7
FTG3	15/08/2012	4.1	6.4	51.00	1.5	5.2	78.00	Nd	0.73	4.9
FTG3	06/03/2013	1.91	3.02	30.97	1.41	2.76	87.86	Nd	0.63	1.69
FTG3	02/05/2014	4.2/4.1 <sup>12</sup>	5.5/5.3 <sup>12</sup>	55/53 <sup>12</sup>	7.0/6.3 <sup>12</sup>	5.5/5.4 <sup>12</sup>	120/120 <sup>12</sup>	1.3/1.2 <sup>12</sup>	5.7/5.3 <sup>12</sup>	3.8/3.7 <sup>12</sup>
FTG3	17/09/2015	1.6	1.9	27.00	0.57	1.6	90.00	Nd	0.41	1.9

DWI Wholesomeness threshold is below

PFOS: 1.0  
PFOA: 5.0

- 1 Calibration of PFOS
- 2 PFBS: perfluorobutanesulphonate, calibration with PFBS
- 3 PFPS: assigned as perfluoropentylsulphonate. Measured by comparison with TDFOS, since no reference sample available
- 4 PFHS: perfluorohexylsulphonate
- 5 TDFOS: tridecylfluorooctylsulphonate
- 6 PFHpS: assigned as perfluoroheptylsulphonate. Measured by comparison with TDFOS, since no reference sample available.
- 7 PFOS: perfluorooctylsulphonate
- 8 TDFOXAS: assigned as tridecylfluorooctane sulphoxide assigned as tridecylfluorooctane sulphone. Measured by comparison with TDFOS, since no reference sample available.
- 9 PFOA: perfluorooctanoic acid
- 10 Calibration with PFOA
- 11 Calibration with TDFOS
- 12 Duplicate analysis

PFOS: perfluorooctylsulphonate  
PFOA: perfluorooctanoic acid

nd: not detected; limit of detection 0.01 ppb for PFOS, 0.03 ppb for PFOA

Prior to 2000, the laboratory analytical technique could only detect the two components perfluorohexylsulphonate (PFHS) and perfluorooctylsulphonate (PFOS). Since 2000, the analytical technique has been enhanced and now nine components of fire-fighting foams can be analysed.